



Buildings



LAA Permit Department of Buildings

Permit Number: 121652782-LAA

Issued: 11/21/2013
3:06 PM

Expires: 11/21/2014

Address: MANHATTAN 100 OVERLOOK TERRACE

Issued to: JEFFREY SOLOMON

Floors: CEL

Business: ABILENE, INC

Licensee No: 0 - 002693

Description of Work: oil: OIL WORK - FUEL GRADE CHANGE

FUEL GRADE WILL CHANGE FROM #6 TO #2 OIL. WE WILL REMOVE WATER LINE & ELECTRIC PRE-HEATER. WE WIL INSTALL AN ANTI-SIPHON VALVE. THERE IS NO CHANGE IN FIRING RATE. NO ACP5 IS REQUIRED. DEP INSTALLATION #CA207193K.

1022MAIL

Emergency Telephone Day or Night: 311

Borough Commissioner:

Commissioner of Buildings:

This permit copy created on 03/30/2026 reflects the Commissioner(s) as of such date.

Tampering with or knowingly making a false entry in or falsely altering this permit is a crime that is punishable by a fine, imprisonment or both.