NYC Buildings

LAA Permit Department of Buildings

Permit Number: *121673545-LAA*

Issued: *10/02/2014 6:04 PM*

Expires: *10/02/2015*

Issued to: PETER CAPUTO

Address: *MANHATTAN 12 EAST 86 STREET*

Business: LEARDON BOILER WORKS.INC

Floors: CEL

Licensee No: O - 005260

Description of Work: *Oil: OIL WORK - FUEL GRADE CHANGE*

CHANGE GRADE OF FUEL FROM #6 T0 #4. THE PRIMARY PRE-HEATER WILL BE REMOVED AND AN ANTI-SYPHON VALVE TO BE INSTALLED. THERE IS NO CHANGE IN FIRING RATE. DEP INSTALLATION#CA101480.

0520GS

Emergency Telephone Day or Night: 311

Borough Commissioner:

Commissioner of Buildings:

This permit copy created on 03/11/2026 reflects the Commissioner(s) as of such date.

Tampering with or knowingly making a false entry in or falsely altering this permit is a crime that is punishable by a fine, imprisonment or both.

OP-35A (2/05)