



Buildings



LAA Permit Department of Buildings

Permit Number: 121875756-LAA

Issued: 12/17/2014
2:40 PM

Expires: 12/17/2015

Address: MANHATTAN 332 EAST 19 STREET

Issued to: LUIS A SEPULVEDA

Floors: CEL

Business: PETRO INC

Licensee No: 0 - 004265

Description of Work: Oil: OIL BURNER/BOILER

REPLACE OIL BURNER ON EXISTING WEIL MCLAIN 788 LOW PRESSURE BOILER (MEA#76-85-E; DOB BOILER#23062; FILED UNDER DOB 101420865) WITH AN INDUSTRIAL COMBUSTION VLG-21 GAS/OIL BURNER (MEA#326-07-E; FIRING RATE=14.2 GPH; OIL INPUT=1,988,000 BTU/HR). BOILER IS CONNECTED TO EXISTING ABOVE GROUND 2000 GALLON #2 F.O. TANK AND EXISTING MASONRY CHIMNEY WITH TERRA COTTA LINER. SEPARATE LAA TO BE FILED BY LMP FOR GAS PIPING WORK.
0716LAAMAIL/1029LC

Emergency Telephone Day or Night: 311

Borough Commissioner:

Commissioner of Buildings:

This permit copy created on 11/26/2025 reflects the Commissioner(s) as of such date.

Tampering with or knowingly making a false entry in or falsely altering this permit is a crime that is punishable by a fine, imprisonment or both.