



Buildings



LAA Permit Department of Buildings

Permit Number: 121877246-LAA

Issued: 02/25/2015
2:00 PM

Expires: 02/25/2016

Address: MANHATTAN 561 BROADWAY

Issued to: ZELJAN UGARKOVIC

Floors: CEL,SUB

Business: ADRIATIC PLBG & HTG CORP

Licensee No: P - 001814

Description of Work: *Plumbing: GAS PLUMBING WORK*

Gas Usage(s): Boiler Pilot

FROM CELLAR TO SUB CELLAR REPLACE APPROX. 20' OF 2" & 4' OF 2 1/2" GAS PIPING TO EXISTING OIL BOILER. IN SUB-CELLAR, INSTALL 1 NEW METER BAR AND 2-2" GAS CONTROL VALVES. PERFORM GAS TEST TO OBTAIN GAS AUTHORIZATION FOR BOILER PILOT. FIRESTOPS WILL NOT BE COMPROMISED. FILING TO CORRECT VIOLATION # 35073141Z. NOTE: BUILDING HAS CELLAR AND SUB CELLAR, NO BASEMENT. OIL BOILER FILED UNDER JOB # 102734702.

**1212IS*

Emergency Telephone Day or Night: 311

Borough Commissioner:

Commissioner of Buildings:

This permit copy created on 03/30/2026 reflects the Commissioner(s) as of such date.

Tampering with or knowingly making a false entry in or falsely altering this permit is a crime that is punishable by a fine, imprisonment or both.