



Buildings



LAA Permit Department of Buildings

Permit Number: 121883550-LAA

Issued: 04/16/2015
3:07 PM

Expires: 04/16/2016

Address: MANHATTAN 281 WEST 11 STREET

Issued to: JOHN ORLANDO JR

Floors: CEL

Business: NEW YORK HEATING CORP

Licensee No: P - 001002

Description of Work: Plumbing: GAS PLUMBING WORK

Gas Usage(s): Heat, Other

EWN: 10021. CON ED SHUT DOWN GAS METER THAT SUPPLIES HEAT AND HOT WATER TO THE BUILDING DUE TO A LEAK IN EXPOSED GAS LINE. LAA IS FOR TESTING EXISTING GAS LINE AND MAKING REPAIRS TO THE FOLLOWING: APPROX 2FT OF NEW 2" PIPING ON EXISTING LINE: APPROX (2) 2" FITTINGS AND APPROX (1) 2" PIPE NIPPLE. GAS TURNED ON BY CON ED 11/1/2014. CON ED CASE#MC108116.

1110JS/0220JS/A0821/5JC

Emergency Telephone Day or Night: 311

Borough Commissioner:

Commissioner of Buildings:

This permit copy created on 06/07/2026 reflects the Commissioner(s) as of such date.

Tampering with or knowingly making a false entry in or falsely altering this permit is a crime that is punishable by a fine, imprisonment or both.