



Buildings



LAA Permit Department of Buildings

Permit Number: 121888680-LAA

Issued: 11/09/2015
12:13 PM

Expires: 05/10/2018

Address: MANHATTAN 61 JANE STREET

Issued to: CARL TERMINE JR

Floors: CEL

Business: ADVANCED P,MECH & SPR COR

Licensee No: P - 001338

Description of Work: Plumbing: GAS PLUMBING WORK

Gas Usage(s): Dryer

IN CELLAR, REGISTER (7)AMERICAN GAS DRYERS AND (2)MAYTAG GAS DRYERS. (EACH DRYER HAS 2 DRYER POCKETS). VENTED THROUGH DRYER EXHAUST SYSTEM. REMOVE (18) GAS FLEX CONNECTORS AND REPLACE WITH APPROX. 54' OF 3/4" GAS PIPING. (APPROX. 6' PER UNIT.) ALL WORK DONR AFTER GAS SHUT OFF VALVE. LAUNDRY ROOM SHOWN ON C OF O #115509. NOTE: FIRESTOP WILL NOT BE COMPROMISED. FILING TO REGISTER REPLACEMENT DRYERS.

1023/5IS____R0502/7M

Emergency Telephone Day or Night: 311

Borough Commissioner:

Commissioner of Buildings:

This permit copy created on 11/24/2024 reflects the Commissioner(s) as of such date.

Tampering with or knowingly making a false entry in or falsely altering this permit is a crime that is punishable by a fine, imprisonment or both.