




**Buildings**



# LAA Permit Department of Buildings

Permit Number: 122298450-LAA

Issued: 07/30/2015  
10:36 AM

Expires: 07/30/2016

Address: MANHATTAN 22 POST AVENUE

Issued to: VINCENT SICILIANO

Floors: OSP

Business: APPROVED OIL CO OF BKLYN

Licensee No: 0 - 004273

Description of Work: oil: OIL WORK

EMERGENCY WK#10753 LAA REQUIRED FOR TEMPORARY MOBILE BOILER. TO PLACE A TEMPORARY MOBILE BOILER UNIT TO PROVIDE HOT WATER TO A MULTI RESIDENTIAL UNIT BUILDING. (BOILER: EASTMOND, MODEL ESP-250, INPUT 10,500,000 BTU'S, UL-2106. BOILER REGISTRATION #163215-01. BURNER: POWERFLAME, MODEL C6-0, UL-MP1836. THERE IS A CURRENT ANNUAL BOILER INSPECTION ON FILE, LIC#4273B.

0714/5MC/0723/5BQ

Emergency Telephone Day or Night: 311

Borough Commissioner:

Commissioner of Buildings:

*This permit copy created on 11/24/2024 reflects the Commissioner(s) as of such date.*

Tampering with or knowingly making a false entry in or falsely altering this permit is a crime that is punishable by a fine, imprisonment or both.