



Buildings

LAA Permit Department of Buildings

Permit Number: 122301231-LAA

Issued: 10/29/2015
12:03 PM

Expires: 10/29/2016

Address: MANHATTAN 68 EAST 11 STREET

Issued to: VINCENT TAVELLA

Floors: CEL,001

Business: TAVELLA PLBG & HTG CORP

Description of Work: Plumbing: GAS PLUMBING WORK

Licensee No: P - 000545

Gas Usage(s): Other

CON EDISON SHUT OFF THE GAS DUE TO A GAS LEAK ON A 1" GAS LINE IN THE CELLAR THAT SUPPLIES GAS TO THE EXISTING INFRA RED HEATER OVER THE CAR WASH ON THE 1ST FLOOR. WE WILL REPLACE APPROXIMATELY 10' OF 1" GAS PIPE USING THE EXISTING CLEVIS HANGERS IN THE CELLAR. NO DISTURBANCE OF ANY MATERIAL. FIRE STOPS WILL NOT BE COMPROMISED. INFRARED HEATER WAS FILED AND SIGNED-OFF UNDER PL#104929712 ON JANUARY 29, 2008. GAS TEST WILL BE COMPLETED.

1006CM*

Emergency Telephone Day or Night: 311

Borough Commissioner:

Commissioner of Buildings:

This permit copy created on 01/19/2026 reflects the Commissioner(s) as of such date.

Tampering with or knowingly making a false entry in or falsely altering this permit is a crime that is punishable by a fine, imprisonment or both.