



**Buildings**



# LAA Permit Department of Buildings

Permit Number: 122304648-LAA

Issued: 01/12/2016  
8:17 AM

Expires: 01/12/2017

Address: MANHATTAN 129 SHERMAN AVENUE

Issued to: MICHAEL F SANTORO

Floors: CEL

Business: APPROVED OIL OF BKLYN, INC

Licensee No: O - 004219

Description of Work: oil: OIL WORK

EMERGENCY REPLACEMENT OF DEFECTIVE BOILER. REMOVE EXISTING OIL BOILER AND INSTALL NEW REPLACEMENT FEDERAL FST-100 BOILER 4,200,000 BTU INPUT 3,348,000 OUTPUT WITH INDUSTRIAL COMBUSTION VLG-42 GAS AND OIL FIRED BURNER. VENTED TO EXISTING CHIMNEY. PW-1 TO FOLLOW BY LICENSED PE WITHIN 60 DAYS. EWN #11345.

1231/5BQ

Emergency Telephone Day or Night: 311

Borough Commissioner:

Commissioner of Buildings:

*This permit copy created on 11/24/2024 reflects the Commissioner(s) as of such date.*

Tampering with or knowingly making a false entry in or falsely altering this permit is a crime that is punishable by a fine, imprisonment or both.