



Buildings



LAA Permit Department of Buildings

Permit Number: 122305585-LAA

Issued: 01/27/2016
4:27 PM

Expires: 03/31/2018

Address: MANHATTAN 122 ORCHARD STREET

Issued to: ANDREW C IMPAGLIAZZO

Floors: BAS

Business: I.M.P. PLBG. & HTG. CORP

Licensee No: P - 001100

Description of Work: Plumbing: GAS PLUMBING WORK

Gas Usage(s): Heat, Other

WE WILL REMOVE THE EXISTING OIL-FIRED BURNER AND REPLACE IT WITH NEW GAS FIRED BURNER ON THE EXISTING WEIL MCLAIN BOILER (DOB BOILER 88066) THE EXISTING BOILER HAS A HOT WATER COIL. WE WILL INSTALL APPROXIMATELY 60LF OF 3" GAS PIPING FROM THE NEW GAS METER ASSEMBLY TO THE EXISTING BOILER. WE WILL INSTALL ONE (1) NEW GAS METER AND ONE (1) NEW GAS RISER. ALL WORK WILL BE PERFORMED IN THE BASEMENT. BTUS FOR POWER FLAME: 2,200,000
0119/6JS

Emergency Telephone Day or Night: 311

Borough Commissioner:

Commissioner of Buildings:

This permit copy created on 03/30/2026 reflects the Commissioner(s) as of such date.

Tampering with or knowingly making a false entry in or falsely altering this permit is a crime that is punishable by a fine, imprisonment or both.