



Buildings



LAA Permit Department of Buildings

Permit Number: 122309180-LAA

Issued: 03/24/2016
11:38 AM

Expires: 05/01/2018

Address: MANHATTAN 39 DOWNING STREET

Issued to: EDWARD J SWEENEY

Floors: CEL,001

Business: CITY GAS HTG SVC CO INC

Licensee No: P - 001891

Description of Work: Plumbing: GAS PLUMBING WORK

Gas Usage(s): Cooking, Water Heater

DUE TO LEAK AND GAS SHUTDOWN REPLACE (2) 2" ELBOWS AND (2) 3/4" GAS VALVES ON THE 1ST FLOOR FOR EXISTING RESTAURANT COOKING AND HOT WATER HEATER. ANSUL VALVE FILED UNDER #120161136.

0314/6VG__R0424/7TO

Emergency Telephone Day or Night: 311

Borough Commissioner:

Commissioner of Buildings:

This permit copy created on 06/07/2026 reflects the Commissioner(s) as of such date.

Tampering with or knowingly making a false entry in or falsely altering this permit is a crime that is punishable by a fine, imprisonment or both.