



**Buildings**



# LAA Permit Department of Buildings

Permit Number: 122315093-LAA

Issued: 07/12/2016  
4:51 PM

Expires: 07/12/2017

Address: MANHATTAN 435 HUDSON STREET

Issued to: DAVID J CATANEO

Floors: OSP

Business: DJC CORP

Licensee No: F - 000575

Description of Work: Fire Suppression: FIRE SUPPRESSION WORK

IN ORDER TO PERFORM FDNY 5 YEAR HYDROSTATIC TEST, REPLACE ONE LEAKING 6" FDNY SIAMESE STANDPIPE CONNECTION ON MORTON STREET SIDE OF BLDG AND ONE LEAKING 6" FDNY SIAMESE SPRINKLER CONNECTION ON LEROY STREET SIDE OF BLDG. REPLACEMENT OF 2 FDNY CONNECTIONS ONLY. NO CHANGE TO PIPING. PERFORM FDNY-WITNESSED\_5 YEAR HYDROSTATIC PRESSURE TEST AND FLOW TEST UPON COMPLETION.\_SYSTEM WILL BE DOWN FOR 3 HOURS.  
0614/6DC\_\_0627/6DC

Emergency Telephone Day or Night: 311

Borough Commissioner:

Commissioner of Buildings:

*This permit copy created on 04/11/2026 reflects the Commissioner(s) as of such date.*

Tampering with or knowingly making a false entry in or falsely altering this permit is a crime that is punishable by a fine, imprisonment or both.