



Buildings

LAA Permit Department of Buildings

Permit Number: 122315967-LAA

Issued: 06/29/2016
11:25 AM

Expires: 06/29/2017

Address: MANHATTAN 320 WEST 96 STREET

Issued to: CLEANTHIS S MEIMAROGLOU

Floors: CEL

Business: ROLANDO MECHANICAL CORP

Description of Work: Plumbing: GAS PLUMBING WORK

Licensee No: P - 001638

Gas Usage(s): Heat, Other

IN CELLAR WE WILL REPLACE APPROXIMATELY 45' OF 2" AND 20' OF 1-1/4" GAS PIPING FROM GAS METER TO EXISTING GAS BOILER. NO GAS PIPING IN PUBLIC HALLWAY AND NO FIRESTOPS TO BE DISTURBED. ALL WORK TO BE DONE IN RESPONSE TO RED TAG BY CON ED (RED TAG #MM00261777) DUE TO GAS LEAK. GAS TEST AND GAS AUTH REQUIRED. EWN APPROVAL#11853. EXISTING BOILER FOR HEAT IS APPROXIMATELY 30 YRS OLD. EXISTING BOILER FOR DOMESTIC HOT WATER WAS FILED UNDER LAA#102264121.

0624/6GM

Emergency Telephone Day or Night: 311

Borough Commissioner:

Commissioner of Buildings:

This permit copy created on 01/20/2026 reflects the Commissioner(s) as of such date.

Tampering with or knowingly making a false entry in or falsely altering this permit is a crime that is punishable by a fine, imprisonment or both.