



Buildings



LAA Permit Department of Buildings

Permit Number: 122316715-LAA

Issued: 07/27/2016
12:01 PM

Expires: 07/27/2017

Address: MANHATTAN 77 READE STREET

Issued to: JOSEPH GEE

Business: GOOD-WILL MEP, LLC

Floors: 004

Licensee No: F - 000970

Description of Work: *Fire Suppression: FIRE SUPPRESSION WORK*

THIS JOB FILE IN CONJUNCTION WITH DOB APPLICATION#140482430, ON 4TH FLOOR APT#4A/C, NEW REARRANGE (11) EXISTING SPRINKLER HEADS FROM EXISTING SPRINKLER SYSTEM. AND ADD (2) NEW SPRINKLER HEADS OFF EXISTING SPRINKLER SYSTEM. INSTALL APPROX 125' OF 1" BLACK PIPE AND REPLACE WITH NEW APPROVED CONCEALED/SIDEWALL SPRINKLER HEADS. TOTAL OF 13 SPRINKLER HEADS. NOTE: SPRINKLER SYSTEM WILL NOT SHUT DOWN FOR MORE THAN 8 HOURS PER DAY.

0711/6LW*

Emergency Telephone Day or Night: 311

Borough Commissioner:

Commissioner of Buildings:

This permit copy created on 05/02/2026 reflects the Commissioner(s) as of such date.

Tampering with or knowingly making a false entry in or falsely altering this permit is a crime that is punishable by a fine, imprisonment or both.