



Buildings

LAA Permit Department of Buildings

Permit Number: 122316859-LAA

Issued: 07/15/2016
1:29 PM

Expires: 07/15/2017

Address: MANHATTAN 360 WEST 22 STREET

Issued to: JONATHAN F CLARK

Floors: CEL 001 thru 012

Business: SANITARY PLBG & HTG CORP

Description of Work: Plumbing: GAS PLUMBING WORK

Licensee No: P - 002341

Gas Usage(s): Cooking

DUE TO LEAK & CON ED SHUTDOWN ON THE M RISER. TEST EXISTING GAS LINES FOR EXISTING STOVES IN (12)RESIDENTIAL APTS-#1M-12M (FLS 1-12). REPLACE APPROX_10' X 1 1/4" GAS PIPE AT THE BASE OF RISER IN CELL WITH TEST TEE & LOCKABLE VALVE. REPLACE GAS APPLIANCE VALVE & GAS FLEX FOR EACH STOVE IN EACH OF THE (12) APTS FIRESTOP WILL NOT BE COMPROMISED.EWN#11898.IN APTS#1M,2M,3M,11M & 12M.REPLACE APPROX 1'X3/4" GAS PIPE & FITTINGS PER APT. IN APT 5M REPLACE 1'X3/4" GAS PIP & FITTINGS & REPLACE 3/4" LOCKWING GAS VALVE.DISCONNECT & PLUG 'M' LINE GAS OVEN RISER NO LONGER IN USE.EST COST NOW \$7,500 A0805/6VG/A0818/6R/V

Emergency Telephone Day or Night: 311

Borough Commissioner:

Commissioner of Buildings:

This permit copy created on 02/10/2026 reflects the Commissioner(s) as of such date.

Tampering with or knowingly making a false entry in or falsely altering this permit is a crime that is punishable by a fine, imprisonment or both.