



Buildings



LAA Permit Department of Buildings

Permit Number: 122580457-LAA

Issued: 09/28/2016
5:46 PM

Expires: 09/28/2017

Address: MANHATTAN 623 WEST 136 STREET

Issued to: PAUL LUNDIN

Floors: 003

Business: KEW FOREST PLBG & HTG INC

Licensee No: P - 001806

Description of Work: Plumbing: GAS PLUMBING WORK

Gas Usage(s): Cooking

EMERGENCY GAS SHUTDOWN BY UTILITY FOR APARTMENT 11 ON THE 3RD FLOOR. WORK COMPLETED AS PER ADMINISTRATIVE CODE 28-105.4.1 AND 28-105.4.3. REPLACE APPROX 1FT OF 3/4" BLACK STEEL GAS PIPE, TWO 3/4 BLACK STEEL ELLS AND 3/4" ISOLATION VALVE AT GAS COOKING STOVE IN APT 11. GAS SYSTEM INSPECTED, TESTED AND RESTORED BY UTILITY PERSONELL. NO GAS TEST REQUIRED. FIRESTOP WILL BE NOT COMPROMISED. EWN#12032.AS OF 9/7/16 AT APPROX.11:30AM THE UTILITY COMPANY RESTORED GAS TO THE APARTMENT.
0909/6TC_A1019/6RM

Emergency Telephone Day or Night: 311

Borough Commissioner:

Commissioner of Buildings:

This permit copy created on 03/05/2026 reflects the Commissioner(s) as of such date.

Tampering with or knowingly making a false entry in or falsely altering this permit is a crime that is punishable by a fine, imprisonment or both.