



Buildings

LAA Permit Department of Buildings

Permit Number: **122581857-LAA**

Issued: **01/19/2017
6:58 PM**

Expires: **01/19/2018**

Address: **MANHATTAN 250 WEST 99 STREET**

Issued to: **JOSEPH GEE**

Floors: **CEL**

Business: **AAA TOTAL PLUMBING, INC**

Description of Work: **Plumbing: WATER PLUMBING WORK**

Licensee No: **P - 002132**

FILE AND REGISTER TO FURNISH AND INSTALL ONE 3" WATTS LF009 (MEA#127-88-M) RPZ IN EXISTING DOMESTIC LINE AT CELLAR AND TO TEST DEVICE AS PER DEP APPROVAL# 14052720. DEVICE DISCHARGE INTO EXISTING FUNNEL DRAIN. THIS LAA IS SUPERSEDING LAA'S 140297756 & 140538951. DEVICE INSTALLATION WILL CONFORM TO SECTION PC608.13.2 TABLE 608.1 AND PC 312.10.2.

1003/6IW_1207/6IW, 1229/16IW

Emergency Telephone Day or Night: **311**

Borough Commissioner: 

Commissioner of Buildings: 

This permit copy created on 01/19/2026 reflects the Commissioner(s) as of such date.

Tampering with or knowingly making a false entry in or falsely altering this permit is a crime that is punishable by a fine, imprisonment or both.