




Buildings



LAA Permit Department of Buildings

Permit Number: 122586503-LAA

Issued: 01/24/2017
5:31 PM

Expires: 01/24/2018

Address: MANHATTAN 60 EAST 12 STREET

Issued to: CARL TERMINE JR

Floors: CEL

Business: ADVANCED P,MECH & SPR COR

Licensee No: P - 001338

Description of Work: Plumbing: GAS PLUMBING WORK

Gas Usage(s): Dryer

IN CELLAR, REGISTER (8) MAYTAG GAS DRYERS. (EACH DRYER HAS 2 DRYER POCKETS). V ENTED THROUGH DRYER EXHAUST SYSTEM. REMOVE (16) GAS FLEX CONNECTORS AND REPLAC E WITH APPROX. 48' OF 3/4" GAS PIPING. (APPROX 6' PER UNIT). ALL WORK DONE AFT ER GAS SHUT OFF VALVE. FIRESTOPS WILL NOT BE COMPROMISED. LAUNDRY ROOM SHOWN O N C OF O #103625908. FILING TO REGISTER REPLACEMENT DRYERS.

1209/6IS

Emergency Telephone Day or Night: 311

Borough Commissioner:

Commissioner of Buildings:

This permit copy created on 06/07/2026 reflects the Commissioner(s) as of such date.

Tampering with or knowingly making a false entry in or falsely altering this permit is a crime that is punishable by a fine, imprisonment or both.