



Buildings



LAA Permit Department of Buildings

Permit Number: 122590810-LAA

Issued: 08/29/2017
4:24 PM

Expires: 08/29/2018

Address: MANHATTAN 220 WEST 24 STREET

Issued to: VITO C VACIRCA

Floors: SUB 006

Business: EAST COAST MECHANICAL LLC

Licensee No: P - 002169

Description of Work: Plumbing: GAS PLUMBING WORK

Gas Usage(s): Cooking, Dryer, Boiler Pilot

EWN13886.REPLACE APPROX(100)LINEAR FEET OF 2" & 3" & 4" GAS PIPE IN SUBCEL TEST ALL RISERS FROM SUBCEL THRU 6TH FL.118 STOVES FOR 118 APTS & 1 METER IN SUBCEL FOR DRYERS & BOILER PILOT. WILL REPIPE 500FT OF 3/4" BLK PIPE FOR APTS ON FLS 1-6 (2,3,5,6,A;A,5,C;6E;3,4,F;4G;4H;2,4K;2M:1,2,4,5Q;1,3,4,6S;5T; 3U) THRU THE FL BEHIND THE STOVE & FIRE STOPPING. WILL TEST ALL APTS ON FLS 1-6; 1 MTR SUBCEL LAUNDRY (REF#140263104 FOR SUBCELLAR LAUNDRY) & PILOT LINE FOR BLR & REQUEST BLUE CARD, APPLIANCES ON EXISTING MTRS COOKING, DRYERS & BLR PILOT GAS. FIRESTOPS RESTORED. NO GAS IN PUBLIC HALLWAYS. EST COST \$25,000__927/7VV

Emergency Telephone Day or Night: 311

Borough Commissioner:

Commissioner of Buildings:

This permit copy created on 08/19/2026 reflects the Commissioner(s) as of such date.

Tampering with or knowingly making a false entry in or falsely altering this permit is a crime that is punishable by a fine, imprisonment or both.