



Buildings



LAA Permit Department of Buildings

Permit Number: 122602004-LAA

Issued: 05/23/2018
12:59 PM

Expires: 05/23/2019

Address: MANHATTAN 161 DUANE STREET

Issued to: ANTHONY M DISABATO

Floors: 005

Business: AMD & ASSOCIATES INC

Licensee No: F - 000356

Description of Work: Fire Suppression: FIRE SUPPRESSION WORK

REFILING EXPIRED LAA NO. 140577828. IN APARTMENT 5A ON THE 5TH FLOOR OFF OF EXISTING SPRINKLER SYSTEM REARRANGE 16 CONCEALED RELIABLE G5 SPRINKLER HEADS WITHIN SAME ROOM USING APPROX 50' OF 1" BLACK PIPE. INSTALL 3 NEW RELIABLE G5 CONCEALED SPRINKLER HEADS USING APPROX 12' OF 1" BLACK PIPE. CAP AND REMOVE 1 CONCEALED SPRINKLER HEAD TO ACCOMODATE INTERIOR RENOVATION WORK (WALL REMOVED) FILED UNDER JOB#122743282. THE 5TH FLOOR SPRINKLER SYSTEM WILL BE DRAINED AND OFFLINE FOR 1 DAY FOR THE DURATION OF 8 HRS.
0213/8CM 0430/8CM

Emergency Telephone Day or Night: 311

Borough Commissioner:

Commissioner of Buildings:

This permit copy created on 05/02/2026 reflects the Commissioner(s) as of such date.

Tampering with or knowingly making a false entry in or falsely altering this permit is a crime that is punishable by a fine, imprisonment or both.