



Buildings

LAA Permit Department of Buildings

Permit Number: 123280412-LAA

Issued: 05/23/2018 12:45 PM

Expires: 05/23/2019

James S. Odds

Address: MANHATTAN 53 WEST 8 STREET

Issued to: MATTHEW ROMAGNUOLO, JR
Business: SPARTAKUS PLBG AND HEATIN

Floors: CEL Licensee No: P - 002154

Description of Work: Plumbing: GAS PLUMBING WORK

Gas Usage(s): Heat, Other

LAA ERROUNEOUSLY FILED AS OIL TO GAS CONVERSION-IN THE CELLAR WE WILL INSTALL APPROXIMATELY 40'OF 1-1/4" GAS PIPING FROM NEW METER TO EXISTING DUAL FUEL BURNER FILED UNDER JOB#140254926.NEW METER WILL BE INSTALLED.TEST GAS LINE FROM NEW METER TO BURNER/HW COIL.THERE WILL BE NO GAS PIPING IN ANY PUBLIC HALLWAYS.FIRESTOPS WILL NOT BE

COMPROMISED.

0502/8GMA A0219/9GM

Emergency Telephone Day or Night: 311

Borough Commissioner:

Commissioner of Buildings:

This permit copy created on 01/01/2026 reflects the Commissioner(s) as of such date.

Tampering with or knowingly making a false entry in or falsely altering this permit is a crime that is punishable by a fine, imprisonment or both.