



**Buildings**

# LAA Permit Department of Buildings

Permit Number: 123283552-LAA

Issued: 04/23/2018  
5:16 PM

Expires: 04/23/2019

Address: MANHATTAN 550 FIRST AVENUE

Issued to: THOMAS MITCHELL

Floors: 018

Business: SIRINA FIRE PROT CORP

Description of Work: *Fire Suppression: FIRE SUPPRESSION WORK*

Licensee No: F - 000422

EWN16065. REARRANGE (1)EXISTING SPRINKLER HEAD ON THE 18TH FLOOR(STORAGE ROOM) WITH 1 FEET LENGTH AND 1" OF BLACK SCHE. 40 PIPING. THE SYSTEM WILL BE DOWN FOR LESS THAN 3 HOURS.

0419/8WM

---

Emergency Telephone Day or Night: 311

Borough Commissioner:

Commissioner of Buildings:

*This permit copy created on 01/22/2026 reflects the Commissioner(s) as of such date.*

Tampering with or knowingly making a false entry in or falsely altering this permit is a crime that is punishable by a fine, imprisonment or both.