



Buildings



LAA Permit Department of Buildings

Permit Number: **140039321-LAA**

Issued: **11/16/2012**
9:54 AM

Expires: **11/16/2013**

Address: **MANHATTAN 225 WEST 25 STREET**

Issued to: **GEORGE J SMITH**

Floors: **BSM**

Business: **EFFICIENT COMB&COOLING CO**

Licensee No: **0 - 005267**

Description of Work: **Oil: OIL WORK - FUEL GRADE CHANGE**

CA # 533585N CHANGE OF GRADE OF FUEL OIL FROM # 6 TO 3 4 FUEL OIL. NO CHANGE IN FIRING RATE. NYS DEC OIL TANK # 2-606196 REMOVE BELOW THE WATER LINE OIL HEATER. INSTALL ANTI-SYPHON AND SHUT OFF VALVE AT OIL TANK. MODIFY OIL PIPING. PROPERLY LABEL OIL TANK AND OIL FILL BOX. OIL PUMP ONLY RUNS WHEN BURNER COMES ON

Emergency Telephone Day or Night: **311**

Borough Commissioner:

Commissioner of Buildings:

This permit copy created on 08/19/2026 reflects the Commissioner(s) as of such date.

Tampering with or knowingly making a false entry in or falsely altering this permit is a crime that is punishable by a fine, imprisonment or both.