




Buildings



LAA Permit Department of Buildings

Permit Number: 140047063-LAA

Issued: 01/02/2013
2:38 PM

Expires: 01/02/2014

Address: MANHATTAN 110 W 14 STREET

Issued to: JULIO MUNDO

Floors: CEL

Business: DYCKMAN PLBG AND HTG INC

Licensee No: P - 001445

Description of Work: *Plumbing: PRIMARY BACKFLOW PREVENTER (RPZ)*

PER DEP'S APPROVAL #12040656 TO INSTALL ONE BACKFLOW PREVENTION DEVICE BY WATTS, MODEL 009 IN THE DIAMETER SIZE OF 2", MEA#127-88-M LOCATE AT CELLAR FOR THE DOMESTIC WATER SERVICE LINE AFTER THE EXISTING WATER METER. NO UNDERGROUND PIPING. NO OTHER MATERIALS WILL BE AFFECT IN THE WORK AREA.

Emergency Telephone Day or Night: 311

Borough Commissioner:

Commissioner of Buildings:

This permit copy created on 06/07/2026 reflects the Commissioner(s) as of such date.

Tampering with or knowingly making a false entry in or falsely altering this permit is a crime that is punishable by a fine, imprisonment or both.