



**Buildings**

# LAA Permit Department of Buildings

Permit Number: 140047679-LAA

Issued: 01/07/2013  
11:39 AM

Expires: 01/07/2014

Address: MANHATTAN 28 EAST 35TH STREET

Issued to: DAVID J CATANEO

Floors: 00C

Business: GATEWAY PLUMBING & HTNG

Description of Work: Plumbing: GAS EQUIPMENT/PIPING

Licensee No: P - 001468

Gas Usage(s): Heat

REMOVE EXISTING GAS HOT WATER BOILER. INSTALL ONE NEW WEIL MCLAIN EGH95 GAS HOT WATER BOILER, 400,000 BTU INPUT, 320,000 BTU OUTPUT MEA 155-00-M. CONNECT TO EXISTING GAS PIPE AND VALVE. RUN NEW FLUE TO EXISTING TILE LINED MASONRY CHIMNEY.

Emergency Telephone Day or Night: 311

Borough Commissioner:

Commissioner of Buildings:

*This permit copy created on 01/22/2026 reflects the Commissioner(s) as of such date.*

Tampering with or knowingly making a false entry in or falsely altering this permit is a crime that is punishable by a fine, imprisonment or both.