



Buildings

LAA Permit Department of Buildings

Permit Number: **140053625-LAA**

Issued: **02/05/2013
11:45 AM**

Expires: **02/05/2014**

Address: **MANHATTAN 903 PARK AVENUE**

Issued to: **ROSARIO GANGI**

Floors: **CEL**

Business: **MICHAEL GANGI P&H CONTRAC**

Description of Work: **Plumbing: PRIMARY BACKFLOW PREVENTER (RPZ)**

Licensee No: **P - 000220**

INSTALL (2) 2" WATTS 009M2-QT RPZ VALVE MEA# 127-88-M. INSTALL 1-2" WATTS 007 DCDA OS & Y VALVE MEA#127-88-M. INSTALL 2-4" FUNNEL DRAINS.

RUN APPROXIMATELY 60' FEET OF 2" COPPER PIPE & 50' OF 4" NO HUB PIPE & 50' OF 2" NO HUB PIPE AS PER DEP APPROVAL #13045315.

Emergency Telephone Day or Night: **311**

Borough Commissioner:

Commissioner of Buildings:

This permit copy created on 01/25/2026 reflects the Commissioner(s) as of such date.

Tampering with or knowingly making a false entry in or falsely altering this permit is a crime that is punishable by a fine, imprisonment or both.