



Buildings

LAA Permit Department of Buildings

Permit Number: 140057337-LAA

Issued: 02/22/2013
7:25 AM

Expires: 02/22/2014

Address: MANHATTAN 110 BENNETT AVENUE

Issued to: MICHAEL BENDJOUYA

Floors: BAS

Business: C C CONTROLLED COMBUSTION

Description of Work: oil: OIL WORK - FUEL GRADE CHANGE

Licensee No: O - 001509

CHANGE GRADE OF FUEL FROM #6 OIL TO #4 OIL. WE WILL REMOVE THE PRE-HEATER AND INSTALL
ANTI-SIPHON VALVES FOR THE EXISTING EQUIPMENT. THERE IS NO CHANGE IN THE FIRING RATE.

Emergency Telephone Day or Night: 311

Borough Commissioner:

Commissioner of Buildings: Acting Commissioner of Buildings

This permit copy created on 01/17/2026 reflects the Commissioner(s) as of such date.

Tampering with or knowingly making a false entry in or falsely altering this permit is a crime that is punishable by a fine, imprisonment or both.