



**Buildings**

# LAA Permit Department of Buildings

Permit Number: 140076496-LAA

Issued: 05/06/2013  
2:07 PM

Expires: 05/06/2014

Address: MANHATTAN 235 WEST END AVENUE

Issued to: JAMES LOPEZ

Floors: CEL

Business: A&C HEATING SERVICES INC

Description of Work: oil: OIL WORK - FUEL GRADE CHANGE

Licensee No: O - 004263

CHANGE GRADE OF FUEL FRO #6 TO #2 FUEL. DISCONNECT PREHEATER, INSTALL ANTI-SIPHON VALVE, REWIRE PUMP TO OPERATE WHEN OIL BURNER IS RUNNING. RE-PIPE FOR #2 OIL OPERATION. NO CHANGE IN FIRE RATE. FIRE STOPS NOT COMPROMISED

Emergency Telephone Day or Night: 311

Borough Commissioner:

Commissioner of Buildings:

*This permit copy created on 01/22/2026 reflects the Commissioner(s) as of such date.*

Tampering with or knowingly making a false entry in or falsely altering this permit is a crime that is punishable by a fine, imprisonment or both.