



**Buildings**



# LAA Permit Department of Buildings

Permit Number: 140082309-LAA

Issued: 05/28/2013  
1:21 PM

Expires: 05/28/2014

Address: MANHATTAN 666 WEST 188TH ST

Issued to: RICHARD MORTMAN

Floors: SUB

Business: RICHARD MORTMAN

Licensee No: 0 - 002633

Description of Work: oil: OIL WORK - FUEL GRADE CHANGE

CONVERT FROM 6 TO 4 OIL. REMOVE PREHEATER AND INSTALL ANTI-SYPHON VALVE.  
FIRING RATE TO REMAIN THE SAME. DEP #CA360884K

Emergency Telephone Day or Night: 311

Borough Commissioner:

Commissioner of Buildings:

*This permit copy created on 05/14/2026 reflects the Commissioner(s) as of such date.*

Tampering with or knowingly making a false entry in or falsely altering this permit is a crime that is punishable by a fine, imprisonment or both.