



**Buildings**

# **LAA Permit Department of Buildings**

Permit Number: **140095206-LAA**

Issued: **07/11/2013  
7:16 AM**

Expires: **07/11/2014**

Address: **MANHATTAN 240 WEST 98 STREET**

Issued to: **CONSTANTINE D'ARCO**

Floors: **CEL**

Business: **S.J. FUEL CO., INC**

Description of Work: **oil: OIL WORK - FUEL GRADE CHANGE**

Licensee No: **O - 002414**

**DICONNECTING OIL SIDE ARM HEATERS, INSTALLING ANTI SIPHONE VALVES ON OIL SUCTION  
LINES, WIRING OIL PUMPS TO RUN ONLY WHEN BURNERS ARE IN OPERATION. CHANGING GRADE OF FUEL  
FROM #6 OIL TO #4 OIL. FIRING RATE TO REMAIN THE SAME. DEP APPLICATION # CA000488J**

---

Emergency Telephone Day or Night: **311**

Borough Commissioner:

Commissioner of Buildings:

*This permit copy created on 01/21/2026 reflects the Commissioner(s) as of such date.*

Tampering with or knowingly making a false entry in or falsely altering this permit is a crime that is punishable by a fine, imprisonment or both.