




Buildings



LAA Permit Department of Buildings

Permit Number: 140126744-LAA

Issued: 10/21/2013
8:18 AM

Expires: 10/21/2014

Address: MANHATTAN 1045 PARK AVENUE

Issued to: JAMES LOPEZ

Floors: CEL

Business: A&C HEATING SERVICES INC

Licensee No: 0 - 004263

Description of Work: oil: OIL WORK - FUEL GRADE CHANGE

CHANGE GRADE OF FUEL FROM #6 OIL TO #4 OIL. DISCONNECT AND REMOVE PRE-HEATER. INSTALL ANTI-SYPHON VALVE AT OIL TANK. RECONFIGURE PIPING FOR #4 OIL OPERATION. NO CHANGE IN FIRE RATING. 5000 GALLON TANK

Emergency Telephone Day or Night: 311

Borough Commissioner:

Commissioner of Buildings:

This permit copy created on 11/16/2024 reflects the Commissioner(s) as of such date.

Tampering with or knowingly making a false entry in or falsely altering this permit is a crime that is punishable by a fine, imprisonment or both.