



Buildings

LAA Permit Department of Buildings

Permit Number: 140128519-LAA

Issued: 10/25/2013
3:22 PM

Expires: 10/25/2014

Address: MANHATTAN 240 WEST 98 STREET

Issued to: JOHN LOVETRO

Floors: CEL,001

Business: N B PLUMBING & HEATING IN

Description of Work: *Fire Suppression: ADD/REPLACE/REPAIR/REARRANGE SPRINKLER HEADS/PIPING*

Licensee No: F - 000926

INSTALL (4) SPRINKLER HEADS ON THE 1ST FLOOR AND (1) SPRINKLER HEAD IN THE CELLAR ON THE EXISTING SERVICE. RUN APPROX 10' OF 1 1/4" AND 20' OF 1" PIPING. FILING IN CONJUNCTION WITH JOB #120733484. THE SIZE OF THE MAIN IS CAPABLE OF HANDLING THE AMOUNT OF SPRINKLER HEADS TO BE INSTALLED.

Emergency Telephone Day or Night: 311

Borough Commissioner:

Commissioner of Buildings:

This permit copy created on 01/21/2026 reflects the Commissioner(s) as of such date.

Tampering with or knowingly making a false entry in or falsely altering this permit is a crime that is punishable by a fine, imprisonment or both.