



**Buildings**



# LAA Permit Department of Buildings

Permit Number: 140135002-LAA

Issued: 11/14/2013  
1:56 PM

Expires: 11/14/2014

Address: MANHATTAN 312 WEST 114TH STREET

Issued to: RICHARD A ADINOLFI

Floors: CEL

Business: SUNATION THERMAL SVCS INC

Licensee No: P - 001365

Description of Work: *Plumbing: PRIMARY BACKFLOW PREVENTER (RPZ)*

*IN CELLAR INSTALL ONE 2" INCH WATTS 007 RPZ DEVICE, MEA#144-83-M DRAINING INTO EXIST FLOOR DRAIN AS PER DEP APP #13047213. NO FIRE STOP OR BUILDING MATERIAL TO BE DISTURBED WHILE PERFORMING WORK*

Emergency Telephone Day or Night: 311

Borough Commissioner:

Commissioner of Buildings:

*This permit copy created on 03/02/2026 reflects the Commissioner(s) as of such date.*

Tampering with or knowingly making a false entry in or falsely altering this permit is a crime that is punishable by a fine, imprisonment or both.