NYC Buildings

LAA Permit Department of Buildings

Permit Number: *140159520-LAA*

Issued: *02/04/2014 10:54 AM* Expires: *02/04/2015*

Issued to: JAMES LOPEZ

Address: *MANHATTAN 107 WEST 86 STREET*

Business: A&C HEATING SERVICES INC

Floors: CEL

Licensee No: O - 004263

Description of Work: *Oil: OIL WORK - FUEL GRADE CHANGE*

CHANGE GRADE OF FUEL OIL FROM #6 TO # 4 OIL. DISCONNECT PREHEATER, INSTALL ANTI-SIPHON VALVE. RE-WIRE PUMP WHEN OIL BURNER IS RUNNING. RE-PIPE FOR #4 OPERATION. NO CHANGE IN FIRING RATE. FIRE STOPS NOT COMPROMISED

Emergency Telephone Day or Night: 311

Borough Commissioner:

Commissioner of Buildings:

This permit copy created on 01/22/2026 reflects the Commissioner(s) as of such date.

Tampering with or knowingly making a false entry in or falsely altering this permit is a crime that is punishable by a fine, imprisonment or both.

OP-35A (2/05)