



Buildings

LAA Permit Department of Buildings

Permit Number: 140168324-LAA

Issued: 02/28/2014
5:51 PM

Expires: 02/28/2015

Address: MANHATTAN 2367 8 AVENUE

Issued to: WILLIAM F HARVEY

Floors: CEL

Business: ORION PLUMBING & HTG CORP

Description of Work: Plumbing: GAS EQUIPMENT/PIPING

Licensee No: P - 001350

Gas Usage(s): Heat

IN CELLAR REPLACE ONE EXISTING GAS BOILER WITH ONE NEW GAS BOILER LOCHINVAR, CBN0647, MEA# 29-08-E, BTU INPUT 645,000, BTU OUTPUT 522,000. EQUIPMENT VENTED THRU EXISTING CHIMNEY. FIRE STOPPING UN COMPROMISED. FOR HEAT ONLY. USING APPROX. 10FT. OF 2" BLACK PIPE.

Emergency Telephone Day or Night: 311

Borough Commissioner:

Commissioner of Buildings:

This permit copy created on 01/22/2026 reflects the Commissioner(s) as of such date.

Tampering with or knowingly making a false entry in or falsely altering this permit is a crime that is punishable by a fine, imprisonment or both.