



**Buildings**



# LAA Permit Department of Buildings

Permit Number: 140251359-LAA

Issued: 09/09/2014  
10:34 PM

Expires: 09/09/2015

Address: MANHATTAN 905 WEST END AVE.

Issued to: MICHAEL S KAPLAN

Floors: BAS

Business: MICHAEL S. KAPLAN

Licensee No: 0 - 005128

Description of Work: oil: OIL WORK - FUEL GRADE CHANGE

*DOWNGRADE FUEL#6 TO #2 FUEL OIL.NO CHANGE IN EGRESS OR OCCUPANCY.ANTISYPHON AND SHUTOFF VALVES TO BE INSTALLED.OIL PUMP TO RUN ONLY ONLY WHEN PUMP RUNS.PREHEATERS TO BE REMOVED.ANY WORK TO BRING UP TO CODE TO BE PERFORMED.*

Emergency Telephone Day or Night: 311

Borough Commissioner:

Commissioner of Buildings:

*This permit copy created on 05/31/2026 reflects the Commissioner(s) as of such date.*

Tampering with or knowingly making a false entry in or falsely altering this permit is a crime that is punishable by a fine, imprisonment or both.