



Buildings



LAA Permit Department of Buildings

Permit Number: 140269876-LAA

Issued: 10/20/2014
11:10 AM

Expires: 10/20/2015

Address: MANHATTAN 310 EAST 115 STREET

Issued to: JOSEPH L TURCHIANO JR

Floors: CEL,001

Business: RICHARDS P AND H CO, INC

Licensee No: P - 001211

Description of Work: *Plumbing: REPLACE/REARRANGE SD*

REPLACE 5 FT. OF DEFECTIVE 4 IN. SCHED. 40 BLACK STEEL FIRE STANDPIPE RISER BETWEEN CELLAR AND 1ST FLOOR. REPLACE ONE (1) DEFECTIVE FIRE STANDPIPE RISER CONTROL VALVE AT FIRST FLOOR WITH NEW UL/FM VICTAULIC #705W BUTTERFLY VALVE. ALL FIRE STOPPING TO BE RESTORED.

Emergency Telephone Day or Night: 311

Borough Commissioner:

Commissioner of Buildings:

This permit copy created on 05/30/2026 reflects the Commissioner(s) as of such date.

Tampering with or knowingly making a false entry in or falsely altering this permit is a crime that is punishable by a fine, imprisonment or both.