



**Buildings**



# LAA Permit Department of Buildings

Permit Number: 140284136-LAA

Issued: 11/21/2014  
1:44 PM

Expires: 11/21/2015

Address: MANHATTAN 10 PARK TERRACE EAST

Issued to: MICHAEL S KAPLAN

Floors: CEL

Business: MICHAEL S. KAPLAN

Licensee No: 0 - 005128

Description of Work: oil: OIL WORK - FUEL GRADE CHANGE

FUEL GRADE CHANGE #6 TO #4 OIL.OIL PRE HEATERS AND HEATERS TO BE REMOVED.TRANSFER PUMP TO RUN ONLY WHEN BURNER RUNS.TO CHANGE IN EGRESS OR OCCUPANCY.BOILER VENTS INTO EXISTING CHIMNEY.SHUT OFF VALVE AND ANTI SYPHON VALVE TO BE INSTALLED.GRADE CHANGE WILL BE COMPLETED BY JUNE 30 2015.ALL WORK TO BRING TO CODE WILL BE DONE.CA128780

Emergency Telephone Day or Night: 311

Borough Commissioner:

Commissioner of Buildings:

*This permit copy created on 03/30/2026 reflects the Commissioner(s) as of such date.*

Tampering with or knowingly making a false entry in or falsely altering this permit is a crime that is punishable by a fine, imprisonment or both.