



LAA Permit Department of Buildings

Permit Number: 140292332-LAA

Issued: 12/15/2014 4:23 PM Expires: 12/15/2015

Issued to: PASQUALE QUARATINO

Address: MANHATTAN 2839 FREDERICK DOUGLAS BOULEVARDBusiness: HARRIS PLUMBING & HEATING

Floors: CEL

Licensee No: P - 001370

Description of Work: Plumbing: PRIMARY BACKFLOW PREVENTER (RPZ)

INSTALL ONE NEW 2" WATTS MODEL # LF009 ON THE EXISTING DOMESTIC SERVICE. EXISTING WATER METER. DISCHARGING IN THE EXISTING FLOOR DRAIN. AS PER DEP # 14052753. MEA # 127-88-M

Emergency Telephone Day or Night: 311

Borough Commissioner:

Commissioner of Buildings:

James S. Oddo

This permit copy created on 11/24/2024 reflects the Commissioner(s) as of such date.

Tampering with or knowingly making a false entry in or falsely altering this permit is a crime that is punishable by a fine, imprisonment or both.