



**Buildings**



# LAA Permit Department of Buildings

Permit Number: 140309306-LAA

Issued: 02/06/2015  
2:09 PM

Expires: 02/06/2016

Address: MANHATTAN 23 WEST 76TH ST.

Issued to: ADOLFO M OSSO

Floors: CEL

Business: OSSO PLBG & HTG CORP

Licensee No: P - 001803

Description of Work: *Plumbing: WATER PLUMBING WORK*

*INSTALLATION OF 2" DOUBLE CHECK VALVE BACKFLOW PREVENTER ON DOMESTIC WATER, MANUFACTURED BY WILKINS, MODEL NO. 950XLT2 LEAD FREE, ASSE NO 1015. INSTALLATION OF 4" DOUBLE CHECK DETECTOR ASSEMBLY BACKFLOW PREVENTER WITH BY-PASS METER MODEL AND DEVICE FOR SPRINKLER SYSTEM, MANUFACTURED BY WILKINS, MODEL NO. 650ADA, ASSE NO 1048. DEP APPROVAL # 15054344.*

Emergency Telephone Day or Night: 311

Borough Commissioner:

Commissioner of Buildings:

*This permit copy created on 03/30/2026 reflects the Commissioner(s) as of such date.*

Tampering with or knowingly making a false entry in or falsely altering this permit is a crime that is punishable by a fine, imprisonment or both.