



Buildings



LAA Permit Department of Buildings

Permit Number: 140327787-LAA

Issued: 03/31/2015
11:10 AM

Expires: 03/31/2016

Address: MANHATTAN 69 TIEMANN PLACE

Issued to: JACK PICCININNI

Floors: CEL

Business: JACK PICCINI, INC

Licensee No: 0 - 005157

Description of Work: oil: OIL WORK - FUEL GRADE CHANGE

CONVERT EXISTING BURNER FROM #6 OIL TO #4 OIL. BOILER ROCKMILLS MP-100, BURNER IC DEG-42P. 3000 GALLON OIL TANK. BOILER #MD 913218-01. DEP# CA181681. BOILER WILL BE CONNECTED TO EXISTING CHIMNEY, WATER LINE HEATER WILL BE REMOVED. PUMP SET WILL ONLY RUN WHEN BURNER IS RUNNING. A ANTI SYPHON DEVICE & SHUT OFF VALVE WILL BE INSTALLED AT THE HIGHEST POINT IN THE OIL LINE.

Emergency Telephone Day or Night: 311

Borough Commissioner:

Commissioner of Buildings:

This permit copy created on 03/05/2026 reflects the Commissioner(s) as of such date.

Tampering with or knowingly making a false entry in or falsely altering this permit is a crime that is punishable by a fine, imprisonment or both.