



Buildings

LAA Permit Department of Buildings

Permit Number: 140340325-LAA

Issued: 04/28/2015
9:56 AM

Expires: 04/28/2016

Address: MANHATTAN 26 ST NICHOLAS PLACE

Issued to: DOV M TRAUM

Floors: OSP, CEL

Business: DMT PLUMBING & HEATING CO

Description of Work: Plumbing: GAS PLUMBING WORK

Licensee No: P - 002157

Gas Usage(s): Heat

INSTALL NEW METER BAR AND RUN APPROX. 15' OF 4" BLACK PIPE AND APPROX 10' OF 3" BLACK PIPE TO EXISTING DUAL FUEL BURNER IC MMG-54P. BOILER IS FEDERAL FST-90 (3,780,000 BTU). EXISTING EQUIPMENT FILED UNDER APPLICATION #101663166. GAS USES ARE HEAT AND TANKLESS COIL.

Emergency Telephone Day or Night: 311

Borough Commissioner:

Commissioner of Buildings:

This permit copy created on 01/20/2026 reflects the Commissioner(s) as of such date.

Tampering with or knowingly making a false entry in or falsely altering this permit is a crime that is punishable by a fine, imprisonment or both.