



Buildings

LAA Permit Department of Buildings

Permit Number: 140340352-LAA

Issued: 04/28/2015
10:13 AM

Expires: 04/28/2016

Address: MANHATTAN 160 RIVERSIDE DRIVE

Issued to: GEORGE J SMITH

Floors: BSM

Business: EFFICIENT COMB&COOLING CO

Description of Work: oil: OIL WORK - FUEL GRADE CHANGE

Licensee No: O - 005267

CB083508 CHANGE OF GRADE OF FUEL FROM # 6 TO # 4 . NO CHANGE IN FIRING RATE. REMOVE
BELOW THE WATER LINE OIL HEATER. INSTALL ANTI-SYPHON & SHUT OFF VALVES AT OIL TANK.
PROPERLY LABEL AND MARK OIL TANK & OIL FILL BOX. NYS DEC # 2-281786 OIL PUMP ONLY RUNS
WHEN BURNER COMES ON. THE EQUIPMENT WILL BE CONVERTED NO LATER THAN JUNE 30, 2015.

Emergency Telephone Day or Night: 311

Borough Commissioner:

Commissioner of Buildings:

This permit copy created on 01/21/2026 reflects the Commissioner(s) as of such date.

Tampering with or knowingly making a false entry in or falsely altering this permit is a crime that is punishable by a fine, imprisonment or both.