



Buildings



LAA Permit Department of Buildings

Permit Number: 140344232-LAA

Issued: 05/06/2015
10:20 AM

Expires: 05/06/2016

Address: MANHATTAN 402 EAST 83RD STREET

Issued to: EDWIN VAZQUEZ

Floors: CEL

Business: METRO P & H INC

Licensee No: P - 001526

Description of Work: Plumbing: GAS PLUMBING WORK

Gas Usage(s): Heat

CON EDISON SHUT DOWN GAS TO BUILDING. FOUND GAS LEAK AFTER GAS METER SUPPLYING EXISTING GAS BOILER FOR BUILDING. PERFORM INTEGRITY TEST ON EXISTING 2" GAS LINE. REPLACE 40 FEET OF 2" GAS PIPING SUPPLYING GAS BOILER FOR HEAT AND DOMESTIC TANKLESS COILS IN CELLAR. NO FIRE STOPS ARE BEING COMPROMISED.

Emergency Telephone Day or Night: 311

Borough Commissioner:

Commissioner of Buildings:

This permit copy created on 05/16/2026 reflects the Commissioner(s) as of such date.

Tampering with or knowingly making a false entry in or falsely altering this permit is a crime that is punishable by a fine, imprisonment or both.