



**Buildings**



# LAA Permit Department of Buildings

Permit Number: 140368251-LAA

Issued: 06/29/2015  
11:12 AM

Expires: 06/29/2016

Address: MANHATTAN 700 WEST 178 STREET

Issued to: JAMES LOPEZ

Floors: CEL

Business: A&C HEATING SERVICES INC

Licensee No: 0 - 004263

Description of Work: oil: OIL WORK - FUEL GRADE CHANGE

CHANGE GRADE OF FUEL FROM #6 OIL TO #2 OIL. DISCONNECT PRE-HEATER, INSTALL ANTI-SYPHON VALVE. RE-WIRE PUMP TO OPERATE WHEN BURNER IS RUNNING. RE-PIPE FOR #2 OIL OPERATION. NO CHANGE IN FIRE RATE. FIRE RATE NOT COMPROMISED. 5000 GALLON OIL TANK

Emergency Telephone Day or Night: 311

Borough Commissioner:

Commissioner of Buildings:

*This permit copy created on 03/29/2026 reflects the Commissioner(s) as of such date.*

Tampering with or knowingly making a false entry in or falsely altering this permit is a crime that is punishable by a fine, imprisonment or both.