



Buildings



LAA Permit Department of Buildings

Permit Number: 140388532-LAA

Issued: 08/11/2015
2:49 PM

Expires: 08/11/2016

Address: MANHATTAN 462 NINTH AVENUE

Issued to: JOHN F MARTINEZ

Floors: BAS

Business: EFFECTIVE PLUMBING CORP

Licensee No: P - 002248

Description of Work: *Plumbing: GAS PLUMBING WORK*

Gas Usage(s): Cooking

DUE TO CON EDISON RED TAG. WE WILL INSTALL ONE 1-1/2 LOCK WING VALVE AFTER THE HEAD OF SERVICE FEEDING THE RESIDENTIAL COOKING GAS. RESIDENTIAL RISER WORK TO BE FILLED UNDER A SEPARATE LAA. EXISTING OVERHEAD FROM THE HEAD OF SERVICE VALVE TO RESTAURANT GAS METER IS HOLDING PRESSURE. EXISTING GAS SHUT OFF VALVE FILED UNDER APPLICATION #103631214 AND RESTAURANT RENOVATION UNDER #122382199. NO FIRE STOPS WILL BE COMPROMISED. THIS IS TO RESTORE GAS TO THE RESTAURANT ONLY.

Emergency Telephone Day or Night: 311

Borough Commissioner:

Commissioner of Buildings:

This permit copy created on 11/16/2024 reflects the Commissioner(s) as of such date.

Tampering with or knowingly making a false entry in or falsely altering this permit is a crime that is punishable by a fine, imprisonment or both.