




Buildings



LAA Permit Department of Buildings

Permit Number: 140392359-LAA

Issued: 08/19/2015
6:17 AM

Expires: 08/19/2016

Address: MANHATTAN 462 9 AV

Issued to: NICK KOULLIAS

Floors: CEL,001

Business: PROTO P&H SERVICES CORP

Licensee No: P - 001285

Description of Work: *Plumbing: GAS PLUMBING WORK*

Gas Usage(s): Cooking, Water Heater

INTEGRITY TESTING OF EXISTING GAS RISER FOR SUSHI RESTAURANT DUE TO CONED SHUTDOWN. GAS LEAK WAS FOUND ON ELBOW JOINT THAT WAS SUBSEQUENTLY TIGHTENED. NO GAS PIPING USED. BLUE CARD & GAS AUTHORIZATION REQUIRED.

Emergency Telephone Day or Night: 311

Borough Commissioner:

Commissioner of Buildings:

This permit copy created on 11/16/2024 reflects the Commissioner(s) as of such date.

Tampering with or knowingly making a false entry in or falsely altering this permit is a crime that is punishable by a fine, imprisonment or both.