



**Buildings**

# LAA Permit Department of Buildings

Permit Number: **140418215-LAA**

Issued: **10/19/2015  
4:25 PM**

Expires: **10/19/2016**

Address: **MANHATTAN 506 WEST 143 ST**

Issued to: **TODD PALLADINO**

Floors: **CEL**

Business: **PALLADINO HEATING SVC INC**

Description of Work: **oil: OIL WORK - FUEL GRADE CHANGE**

Licensee No: **O - 005277**

**OIL WORK: FUEL GRADE CHANGE - CHANGE GRADE OF FUEL FROM #4 TO #2 OIL WITH THE REPLACEMENT OF EXISTING BURNER. ANYI-SYPHON VALVE TO BE INSTALLED OIL PUMP TO RUN ONLY WHEN BURNER IS IN OPERATION. NO DEP INSTALLATION # ISSUED. NO CHANGE IN FIRING RATE. NO CHANGE IN USE, EGRESS OR OCCUPANCY UNDER THIS APPLICATION.**

---

Emergency Telephone Day or Night: **311**

Borough Commissioner:

Commissioner of Buildings:

*This permit copy created on 01/20/2026 reflects the Commissioner(s) as of such date.*

Tampering with or knowingly making a false entry in or falsely altering this permit is a crime that is punishable by a fine, imprisonment or both.