



Buildings

LAA Permit Department of Buildings

Permit Number: **140473798-LAA**

Issued: **03/22/2016
3:44 PM**

Expires: **03/22/2017**

Address: **MANHATTAN 401 EDGEcombe AVE**

Issued to: **DARREN LUNDIN**

Floors: **BAS 001 thru 006**

Business: **KEW FOREST PLBG & HTG INC**

Description of Work: **Plumbing: GAS PLUMBING WORK**

Licensee No: **P - 001525**

Gas Usage(s): Cooking

DUE TO CON ED SHUT DOWN ON 3/21/2016. TEST ALL GAS RISERS TO THE EXISTING GAS METERS AND COOKING APPLIANCES IN ALL APARTMENTS OF 401 EDGEcombe AVE. REPLACE ALL APPLIANCE VALVES, AND TEST ALL LINES FOR INTEGRITY. INSTALL UTILITY APPROVED LOCKABLE VALVES AT THE BASE OF EACH RISER WITH MINIMAL FITTINGS AND NIPPLE WORK. RISER VALVES ARE 1 1/4" AND 3/4". IF ANY OTHER WORK IS REQUIRED A FOLLOW UP LAA WILL BE SUBMITTED WITH FULL DESCRIPTION.

0405/6DL

Emergency Telephone Day or Night: **311**

Borough Commissioner:

Commissioner of Buildings:

This permit copy created on 01/22/2026 reflects the Commissioner(s) as of such date.

Tampering with or knowingly making a false entry in or falsely altering this permit is a crime that is punishable by a fine, imprisonment or both.