



Buildings



LAA Permit Department of Buildings

Permit Number: **140513004-LAA**

Issued: **06/23/2016
2:00 PM**

Expires: **06/23/2017**

Address: **MANHATTAN 420 EAST 55 STREET**

Issued to: **GEORGE BASSOLINO III**

Floors: **CEL**

Business: **G.BASSOLINO PLUMBING LTD**

Licensee No: **P - 001044**

Description of Work: **Plumbing: WATER PLUMBING WORK**

DEP MANDATED INSTALLATION OF (1) 6" WILKINS 375 RPZ ON EXISTING COMBINED SERVICE AND (1) 6" WILKINS 350 DCDA ON EXISTING FIRE SERVICE. DEVICES APPROVED UNDER FCCCHR OF USC MANUAL SECTION 10. DEP APPROVAL #15055556. INSTALL APPX 20 FEET OF 6" COPPER AND 20 FEET OF BLACK PIPE AND FITTINGS. CTE SYSTEM PIPING. INSTALL APPX 15 FEET OF 6" INDIRECT WASTE PIPE TO SPILLOVER EXISTING FLOOR DRAIN. ALL PIPING FULLY EXPOSED.

Emergency Telephone Day or Night: **311**

Borough Commissioner:

Commissioner of Buildings:

This permit copy created on 09/16/2026 reflects the Commissioner(s) as of such date.

Tampering with or knowingly making a false entry in or falsely altering this permit is a crime that is punishable by a fine, imprisonment or both.